



**Ministry of Agro-Industry, Food Security,
Blue Economy and Fisheries
(Agro-Industry and Food Security Division)
Addendum No. 2**

Please refer to Procurement Exercise Reference: AGRO/IFB/2025/3560 - Supply, Installation, Testing and Commissioning of New Variable Refrigerant Volumes (VRVs) and Upgrading of Electrical System at Food Technology Laboratory, Réduit published on 20 March 2025 on the e-procurement system.

2. Bidders are requested to take note that the Energy Services Division will provide the soft copy in CAD format exclusively to the successful bidder. The specifications and PDF layouts supplied are adequate for the preparation of the bidding process.

3. Bidders are also requested to take note that the minimum flow rate mentioned in the specifications (page 34) applies to the extractor and supply fans. The AC3 split unit is specified to have a capacity of 12,000 BTU/hr, which is unrelated to the flow rate discrepancy noted.

4. Bidders are requested to take note that the deadline for submission of bids has been maintained as per key activity schedule.

5. Moreover, Bidders are also requested to take note that a site visit has already been effected on Wednesday 02 April 2025 at 1030 hrs at the Food Technology Laboratory, Réduit in the presence of the representatives of the Energy Services Division and Food Technology Laboratory.

For any query or additional information, bidders are requested to contact Officer-in-Charge, Food Technology Laboratory on 466-1435.

**Ministry of Agro-Industry, Food Security, Blue Economy and Fisheries
(Agro-Industry and Food Security Division)
Port-Louis
17 April 2025**